



- Jerry Lee, Chair
- Richard Jackson
- Neal Black
- Tina Keys
- Regina Elmi

INVITATION TO BID

Window Replacement
at
Woodside East Apartments 16240 NE 14th St, Bellevue, WA 98008

March 26, 2026

ADDENDUM NO. 2

This addendum is used to clarify, change, delete, add to or substitute items in the original contract documents.

BID DATE: April 2, 2026, at 11:00 am

QUESTIONS DEADLINE: Thursday, March 26, 2026, at 9:00 am

NUMBER OF PAGES: 1

CONTRACT NUMBER: AW2600831

NOTICE TO BIDDERS: Bidders are hereby notified of the following changes and/or clarifications to the Contract Documents for this project:

QUESTIONS/CLARIFICATION:

Q: Window Sizing: Ply Gem's maximum window size is 32 sq ft, but one of the required windows is 48 sq ft. I can accommodate this, but it will require using a different manufacturer for that specific unit.

A: Window sizes to remain as existing. If Ply Gem does not make the size required to match existing sizes, then contractor is to switch to a manufacturer that does supply existing size and meets required specifications. Limit substituted manufacturer to only windows that cannot be matched by manufacturer called out in specifications (Ply Gem Windows).

All other provisions of the Contract Documents remain unchanged.

END OF ADDENDUM NO. 2