

ADDENDUM:

#1

TODAY'S DATE:

3/29/2024

PROJECT NAME:

600 BUILDING ELECTRICAL UPGRADES

CONTACT / TITLE:

Don Hatfield

PROJECT MANAGER

PHONE / EMAIL:

206-574-1213

donaldh@kcha.org

This Addendum is used to Identify Items in the Original Documents with Action as Follows:

BID

RFQ

RFP

CLARIFY

CHANGE

DELETE

ADD

SUBSTITUTE

1 Page(s) Total for this Addenda including this page.

Question: Your looking for an 800 Amp freestanding Switchboard outside can you switch it to a Nema 3R 800 Amp Panel Board with a CT can?

Answer: As a substitute, and with KCHA's acceptance of a Substitution Request Form listed in your bid documents (pages 230 and 231), the contractors proposed alternative to use a separate CT can and panelboard is acceptable provided it is all installed in a single, NEMA 3R, line and match, lockable cabinet to meet all Code and PSE requirements.

END OF ADDENDUM # 1