

ADDENDUM:

2

TODAY'S DATE:

09.12.23

PROJECT NAME: Pepper Tree Envelope

CONTACT / TITLE: Amy Kurtz

PROJECT MANAGER

PHONE / EMAIL: Amyk@kcha.org

206-574-1283

This Addendum is used to Identify Items in the Original Documents with Action as Follows:

BID

RFQ

RFP

CLARIFY

CHANGE

DELETE

ADD

SUBSTITUTE

1 Page(s) Total for this Addenda including this page.

1. **ADD:** Contractor to remove and replace roof soffits at noted shear walls (per page S2.0, S2.1) to complete installation of LTP4 and install new blocking per detail 3/S3.0.
2. **ADD:** Contractor to remove and replace areas of deck soffits as needed to complete structural blocking and bracket installation per plan S3.0.
3. **ADD:** Contractor to include weather protection of building as part of base bid.
4. **CLARIFY: DECKS:** Contractor to remove existing dura-deck vinyl membrane. Including removal of all adhesive and repair existing concrete surface as needed for the fluid applied deck coating application.

END OF ADDENDUM # 2