



Board of Commissioners
Doug Barnes, *Chair*
Susan Palmer, *Vice-Chair*
John Welch
TerryLynn Stewart
Regina Elmi

Executive Director/CEO
Robin Walls

INVITATION TO BID

ADA Pool Bathroom
at
Carrington Apartments 2501 148th Ave SE, Bellevue WA 98007

December 1, 2022

ADDENDUM NO. 2

This addendum is used to clarify, change, delete, add to or substitute items in the original contract documents.

BID DATE: ~~December 2, 2022 at 1:00 pm~~ Thursday, December 8, 2022 at 2:00 pm

CONTRACT NUMBER: DW2201231

BIDDERS ARE HEREBY NOTIFIED OF THE FOLLOWING CHANGES AND/OR CLARIFICATIONS TO THE CONTRACT DOCUMENTS FOR THIS PROJECT:

Questions:

1. Q: Is their electric strike card reader & ADA auto operator push button?
A: The door is fob released, but does not currently have an auto opening arm or push button.
2. Q: Is the ceiling above the work area Post tension or Structural reinforced with rebar only?
A: It appears the concrete deck above the bathroom areas is standard steel reinforced and not post tensioned. Because this cannot be confirmed the contractor is required to x-ray any locations before penetrating.

All other provisions of the Contract Documents remain unchanged.

END OF ADDENDUM NO. 2