

ADDENDUM:

1

TODAY'S DATE:

9/1/23

PROJECT NAME: Southridge House Fire Monitoring System

CONTACT / TITLE: Carl Frankel

PROJECT MANAGER

PHONE / EMAIL: 206.574.1249

carlf@kcha.org

This Addendum is used to Identify Items in the Original Documents with Action as Follows:

BID

RFQ

RFP

CLARIFY

CHANGE

DELETE

ADD

SUBSTITUTE

1 Page(s) Total for this Addenda including this page.

1. CLARIFY: Project Scope of Work Page 14 Division 28 Fire Monitoring states that ADA units 101, 102, 104, 106, 107 and 108 to receive audible and visual notification devices. Contractor to follow System Code Requirements on page FA.01 of drawings and provide and install audible/visual coverage throughout building and in all dwelling units. Visual notification devices to be included in All dwelling unit living rooms, bedrooms and bathrooms.

2. ADD: Hazmat report is included with bid documents. Contractor to review report and will be responsible to provide all asbestos abatement necessary prior to installing fire monitoring components.

END OF ADDENDA # 1