



CAPITAL CONSTRUCTION DEPARTMENT  
700 ANDOVER PARK WEST  
TUKWILA, WA 98188

**CONSTRUCTION ADDENDUM: 2**

1/23/2026

**PROJECT NAME:** Briarwood Balcony Resurfacing

**PROJECT MANAGER:** Carl Frankel

**PHONE NUMBER:** 206-574-1249      **EMAIL ADDRESS:** CarlF@kcha.org

**This Addendum is used to Identify Items in the Original Documents with Action as Follows:**

**CLARIFY**       **CHANGE**       **DELETE**  
 **ADD**       **SUBSTITUTE**

**Page(s) Total for this Addenda including this page 1**

---

1. *DELETE: Contractor to bring Rhino coating up to heat pump pad and come up the sides and over the top of the pad. Prime pad prior to top coats.*
2. *CHANGE: Rhino Lining coatings to be installed up to the bottom edges of the heat pump pad.*
3. *CLARIFY: Rhino Lining applicator is required to be certified by Rhino Linings Corp.*

**END OF CONSTRUCTION ADDENDUM: 2**