

ADDENDUM:

2

TODAY'S DATE:

06.08.23

PROJECT NAME: Glenview Heights Exterior Upgrades

CONTACT / TITLE: Amy Kurtz

PROJECT MANAGER

PHONE / EMAIL: 206.574.1283

AmyK@kcha.org

This Addendum is used to Identify Items in the Original Documents with Action as Follows:

☒ **BID**

☐ **RFQ**

☐ **RFP**

☒ **CLARIFY**

☐ **CHANGE**

☐ **DELETE**

☐ **ADD**

☐ **SUBSTITUTE**

1 Page(s) Total for this Addenda including this page.

QUESTIONS:

1. Does existing sheeting need to be removed for blocking new siding details?

ANSWER: Yes- Refer to Scope of work Division 5 Section B. Metal Ladders.

2. Does the roofing tie offs need to be powder coated or can we paint?

ANSWER: Roof tie offs (Fall Arrest Anchors) will be powder coated per plan.

3. Details are calling for backer rod, if the windows are tight can we use sealant?

ANSWER: No- Backer rod will be installed per plan.

4. Has KCHA determined the swing on the new doors?

ANSWER: Yes-

END OF ADDENDA # 2