

CONSTRUCTION ADDENDUM: 02

10/2/2025

PROJECT NAME: Newport Fire Alarm System Replacement**PROJECT MANAGER:** Amy Kurtz**PHONE NUMBER:** 206-574-1283**EMAIL ADDRESS:** Amyk@kcha.org

This Addendum is used to Identify Items in the Original Documents with Action as follows:

- | | | |
|--|--|--|
| <input checked="" type="checkbox"/> CLARIFY | <input type="checkbox"/> CHANGE | <input type="checkbox"/> DELETE |
| <input checked="" type="checkbox"/> ADD | <input type="checkbox"/> SUBSTITUTE | |

Page(s) Total for this Addenda, including this page 1

CLARIFY

1. The job duration is 90 calendar days, not 120 days. Any reference to 120 days in the Scope of Work (SOW) should be disregarded.
2. Per Specification 283100 Section 1.1 Summary
Replace the existing fire alarm system in its entirety. All panels, devices, and cables shall be removed entirely and replaced. This includes all common area devices, as well as devices within a dwelling unit, such as 120VAC smoke alarms, smoke detectors of any type, strobes of any type, and heat detectors of any type. This includes all devices not directly related to the existing system.

ADD

1. Contractor to include the removal of all existing wire mold associated with the fire alarm system. The contractor will be responsible for repairing any areas damaged by the removal and painting the area to match the existing one.

END OF CONSTRUCTION ADDENDUM: 2