



CONSTRUCTION ADDENDUM: 1

5/29/2026

PROJECT NAME: Paramount House Fire Alarm System Replacement

PROJECT MANAGER: Carl Frankel

PHONE NUMBER: 425-891-3317 **EMAIL ADDRESS:** Carlfr@kcha.org

This Addendum is used to Identify Items in the Original Documents with Action as Follows:

- CLARIFY** **CHANGE** **DELETE**
 ADD **SUBSTITUTE**

Page(s) Total for this Addenda including this page 1

1. CLARIFY: Where the RE symbols are depicted, the contractor is to remove existing devices and replace with new addressable devices. See Plan General Requirement Notes on pages FA5, FA5.01, FA5.02, FA5.03.

2. CLARIFY: The scope of work for this project includes all elevator devices and testing for a code compliant and AHJ Fire Marshal approved FAS for the elevator.

END OF CONSTRUCTION ADDENDUM: 1