



**KING COUNTY HOUSING AUTHORITY
INVITATION FOR BID
Mechanical & Electrical Work
At
KIRKLAND PLAZA APARTMENTS
ADDENDUM #3**

Effective October 14th, 2022, this Addendum #3 shall be considered part of the Invitation for Bid Documents.

Revisions/Additions/Clarifications to Exhibit C - Mechanical Work Specifications:

1. Bathroom Fan Model BreezSlim Ventilation Fans - SLM70D will be changed to BreezSlim Ventilation Fans - SLM70ELED to provide more light for the residents in the bathroom.
2. There is no expectation to run a brand new circuit from the panel in units to the service outlets required for the mini split systems.
3. It was pointed out that the bathroom fans on the summary were for only the two common area bathroom fans. This was done with the intention of separating the total cost per apartment from the common area cost. Please combine the cost of the bathroom fans, controls and heating upgrades in the unit on that line and use the line addressing the common area bath fans for those fans and controls only.

Bidder's Requirements:

4. King County Housing Authority Weatherization has elected to waive the mandatory attendance requirement for the pre-bid meeting.

Bid Due Date:

5. King County Housing Authority Weatherization has elected to extend the bid due date to Monday October 31st, at 2:30 pm.