



## INVITATION TO BID

Meadows on Lea Hill Fire Alarm System  
at

Meadows on Lea Hill Apartments, 12505 SE 312<sup>th</sup> St, Auburn, WA 98092

March 11, 2022

### ADDENDUM NO. 1

This addendum is used to clarify, change, delete, add to or substitute items in the original bid documents.

BID DUE DATE: Thursday March 24, 2022 at 2:00 P.M.

QUESTION DEADLINE: Seven (7) calendar days prior to bid due date

NUMBER OF PAGES: 1            ATTACHMENTS: N/A

CONTRACT NUMBER: HW2200931

### NOTICE TO PLAN HOLDERS

Plan holders are hereby notified of the following changes and/or clarifications to the Contract Documents for this project.

### QUESTIONS:

Question: Spec section 28 30 00 3.02 Labeling; states: "Label alarm initiating devices with ½-inch by 1-inch lamacoid nameplates, indicating control panel point designation. Locate nameplates in the vicinity of the device as approved by the Owner." Please confirm Lamacoid AKA Phenolic labels are required at EACH Initiating device

Answer: The labeling is required only at the fire alarm control panels and at the NAC panels but not at the devices.

### END OF ADDENDUM NO. 2